

Item no.: 273-101
 Product description: PUSH-WIRE CONNECTOR FOR JUNCTION BOXES; 5-CONDUCTOR TERMINAL BLOCK; PUSH-WIRE CONNECTION



Packing unit 1000 10*100 pieces

pole count	5
Cross section from [mm ²]	0,75 mm ²
Cross section to [mm ²]	1,5 mm ²
Cross section from [AWG]	18 AWG
Cross section to [AWG]	16 AWG
Connection method	PUSH-WIRE CONNECTION
Number of strands	5
Voltage CSA	600 V
Voltage UL	600 V
Current UL	10 A
Current CSA	10 A
Measured voltage EN	400 V
Measured shock voltage	4 kV
Pollution degree	2
Current intensity EN	18 A
Weight	2,52 g
Color	grey
Wiring type	Side-entry
No. of connection Points	5
No. of potentials	1
Height	8,6 mm
Height	0,339 in
Width	17,5 mm
Width	0,689 in
Depth	18,5 mm
Depth	0,728 in
Strip length from	10 mm
Strip length to	13 mm
Strip length	0,45 in

	Admission office	Approval no.	Voltage [V]	Current [A]	Cross section [mm ²]
273-101	ASTA	Cert.No.167	400	17,5	0,5-1,5
273-101	BBJ	B/12/694/03	400	18	1,5
273-101	BV	11914/AO	400	18	1,5
273-101	CCA	DK2017	400	18	1,5
273-101	CSA	154112-1059435	600	10	20-16"s"
273-101	CSM	017956	400	18	1,5
273-101	DEMKO	99-00683	400	18	1,5
273-101	Dep.MaE	CS4573N	300		5x(0,5-1,5)
273-101	DNV	E6998	400	18	1,5
273-101	FIMKO	F113213	400	18	1,5

273-101	GL	17294-00HH	400	18	1,5
273-101	KEMA	97.1394.01	400	18	0,5-1,5
273-101	LCIE	190863B	380		1,5
273-101	NEMKO	99101318	400	18	1,5
273-101	ÖVE	1193-033-00	400	18	1,5
273-101	RosTesT	B09523	400	18	1,5
273-101	SEMKO	9921002/01-03	400	18	1,5
273-101	SEV	99,770286,01	400	18	1,5
273-101	UL	E69654	600	10	20-16"s"
273-101	VDE	123900	400	18	1,5

Sorting criteria: admission office - approval number

© WAGO Kontakttechnik GmbH & Co. KG

Specifications are subject to changes and errors may be expected