

Item no.: 273-102
 Product description: PUSH-WIRE CONNECTOR FOR JUNCTION BOXES; 4-CONDUCTOR TERMINAL BLOCK; PUSH-WIRE CONNECTION



Packing unit 1000 10*100 pieces

pole count	4
Cross section from [mm ²]	1 mm ²
Cross section to [mm ²]	2,5 mm ²
Cross section from [AWG]	14 AWG
Cross section to [AWG]	12 AWG
Connection method	PUSH-WIRE CONNECTION
Number of strands	4
Voltage CSA	600 V
Voltage UL	600 V
Current UL	20 A
Current CSA	20 A
Measured voltage EN	400 V
Measured shock voltage	4 kV
Pollution degree	2
Current intensity EN	24 A
Weight	2,94 g
Color	dark grey
Wiring type	Side-entry
No. of connection Points	4
No. of potentials	1
Height	9,6 mm
Height	0,378 in
Width	17,5 mm
Width	0,689 in
Depth	19,5 mm
Depth	0,768 in
Strip length from	10 mm
Strip length to	13 mm
Strip length	0,45 in

	Admission office	Approval no.	Voltage [V]	Current [A]	Cross section [mm ²]
273-102	ASTA	Cert.No.167	400	24	0,75-2,5
273-102	BBJ	B/12/694/03	400	24	2,5
273-102	BV	11914/AO	400	24	2,5
273-102	CCA	DK2017	400	24	2,5
273-102	CSA	154112-1059435	600	20	18-12"s"
273-102	CSM	017956	400	24	2,5
273-102	DEMKO	99-00683	400	24	2,5
273-102	Dep.MaE	CS4573N	300		4x(0,75-2,5)
273-102	DNV	E6998	400	24	2,5
273-102	FIMKO	F113213	400	24	2,5

273-102	GL	17294-00HH	400	24	2,5
273-102	KEMA	97.1394.01	400	24	0,75-2,5
273-102	LCIE	190863A	380		2,5
273-102	NEMKO	99101318	400	24	2,5
273-102	ÖVE	1193-033-00	400	24	2,5
273-102	RosTesT	B09523	400	24	2,5
273-102	SEMKO	9921002/01-03	400	24	2,5
273-102	SEV	99,770286,01	400	24	2,5
273-102	UL	E69654	600	20	18-12"s"
273-102	VDE	123899	400	24	2,5

Sorting criteria: admission office - approval number

© WAGO Kontakttechnik GmbH & Co. KG

Specifications are subject to changes and errors may be expected