

Item no.: 273-103
 Product description: PUSH-WIRE CONNECTOR FOR JUNCTION BOXES; 8-CONDUCTOR TERMINAL BLOCK; PUSH-WIRE CONNECTION



Packing unit 500 10*50 pieces

pole count	8
Cross section from [mm ²]	1 mm ²
Cross section to [mm ²]	2,5 mm ²
Cross section from [AWG]	14 AWG
Cross section to [AWG]	12 AWG
Connection method	PUSH-WIRE CONNECTION
Number of strands	8
Voltage CSA	600 V
Voltage UL	600 V
Current UL	20 A
Current CSA	10 A
Measured voltage EN	400 V
Measured shock voltage	4 kV
Pollution degree	2
Current intensity EN	24 A
Weight	4,67 g
Color	dark grey
Wiring type	Side-entry
No. of connection Points	8
No. of potentials	1
Height	17 mm
Height	0,669 in
Width	17,5 mm
Width	0,689 in
Depth	19,5 mm
Depth	0,768 in
Strip length from	10 mm
Strip length to	13 mm
Strip length	0,45 in

	Admission office	Approval no.	Voltage [V]	Current [A]	Cross section [mm ²]
273-103	ASTA	Cert.No.167	400	24	0,75-2,5
273-103	BBJ	B/12/694/03	400	24	2,5
273-103	BV	11914/AO	400	24	2,5
273-103	CCA	DK2017	400	24	2,5
273-103	CSA	154112-1059435	600	10	20-16"s"
273-103	CSM	017956	400	24	2,5
273-103	DEMKO	99-00683	400	24	2,5
273-103	Dep.MaE	CS4573N	300		8x(0,75-2,5)
273-103	DNV	E6998	400	24	2,5
273-103	FIMKO	F113213	400	24	2,5

273-103	GL	17294-00HH	400	24	2,5
273-103	KEMA	97.1394.01	400	18	0,75-2,5
273-103	LCIE	273898	380		2,5
273-103	NEMKO	99101318	400	24	2,5
273-103	ÖVE	1193-033-00	400	24	2,5
273-103	RosTesT	B09523	400	24	2,5
273-103	SEMKO	9921002/01-03	400	24	2,5
273-103	SEV	99,770286,01	400	24	2,5
273-103	UL	E69654	600	20	16-14"s"
273-103	VDE	123899	400	24	2,5

Sorting criteria: admission office - approval number

© WAGO Kontakttechnik GmbH & Co. KG

Specifications are subject to changes and errors may be expected